

The Village of Baltimore Public Water System Consumer Confidence Report 2016



Village of Baltimore
103 West Market Street
Baltimore, Ohio 43105

The Village of Baltimore Drinking Water Consumer Confidence Report For 2016

Introduction

The Village of Baltimore has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

The Village of Baltimore continues to work diligently to provide safe potable drinking water to all of its consumers. The Village has trained and certified some of its employees in backflow prevention to help ensure the safety of our potable drinking water.

The Village of Baltimore has a current, unconditioned license to operate our water system.

Source Water Information.

The Village of Baltimore is a community public water system serving approximately 3600 people. The water system operates three wells that pump approximately 250,000 gallons of water per day.

The drinking water protection zone is combined by two protection areas:

- The Inner Protection Zone provides ground water to the wells for one year of pumping. A chemical spill in this zone poses a greater threat to the drinking water, so this area warrants a more stringent protection.
- The Outer Protection Zone is the additional area that contributes water when the wells are pumped for five years.

Together, they comprise the drinking water source protection area.

In 2002 the Ohio Environmental Protection Agency (OEPA) completed a Source Water Protection Assessment (SWAP) of the Village of Baltimore. This assessment indicates that the Village of Baltimore's source of drinking water has a low susceptibility to contamination because the depth to the bottom of the confining layer in the sand and gravel buried valley aquifer is greater than 100' below the ground surface. This layer provides protection from contaminants from infiltrating from the grounds surface to the aquifer and that the water quality results do not indicate that contamination has impacted the aquifer.

The Village of Baltimore is part of the Fairfield County Regional Well Head Protection Team and we are working diligently to provide the safest Source Water Protection for our well's that we possibly can. A copy of the Source Water Protection plan can be obtained by contacting the village offices at (740) 862-4491.

Sources of contamination to drinking water

The sources of drinking water both tap water and bottled water includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Who needs to take special precautions

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water.

The EPA requires regular sampling to ensure drinking water safety. The Village of Baltimore conducted sampling for Nitrates; Bacteria; and Disinfection By-Product contaminant's during 2016. Samples were collected for a total of thirty different contaminants most of which were not detected in the Village of Baltimore water supply. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

Monitoring and Reporting Violations

NONE TO REPORT

Water Quality Monitoring Information-Table of Detected Contaminants

Listed below is information on those contaminants that *were found* in the Village of Baltimore drinking water.

Contaminants (Units)	MCL G	MCL	Level Found	Range of Detectio ns	Violation	Sample Year	Typical Source of Contaminants
Bacteriological							
Total Coliform Collected 36 Samples	0	>1 Monthly	0	0-1	No	2016	Naturally Present in the Environment
Inorganic Contaminants							
Anitimony, Barium, Beryllium, Cadmium, Chromium, Cyanide, Fluoride, Mercury, Nickel, Selenium, and Thallium	Misc	Misc	Below MCL'S	Misc	No	2011	Erosion of Natural Deposits
Copper	1.3	AL=1.3	.083	N/A	No	2014	Corrosion of Household Plumbing
Lead	15	AL=15	0	N/A	No	2014	Corrosion of Household Plumbing
Arsenic	0	10	4.8	N/A	No	2011	Erosion of Natural Deposits
Nitrate	10	10	< .10	N/A	No	2016	Run off from fertilizer use; leaching from septic tanks:sewage:Erosion of natural deposits

Synthetic Organic Contaminants including Pesticides and Herbicides							
Atrazine	3.0	3.0 ug/l	<.3	N/A	No	2011	Run off from herbicide used on row crops
Alachlor	2.0	2.0 ug/l	<.20	N/A	No	2011	Run off from herbicide used on row crops
Simazine	4.0	4.0 ug/l	<.35	N/A	No	2011	Herbicide Run off
Volatile Organic Contaminants							
Total Trihalomethanes (TTHM)	N/A	80	<3.0	<2 – 8.14	No	2016	By-Product of Drinking Water Chlorination
Haloacetic Acids (HAA5)	N/A	60	<6.0	<6.0	No	2016	By-Product of Drinking Water Chlorination
Residual Disinfectants							
Total Chlorine	4.0	4.0	1.5	0.6 – 1.9	No	2016	Water additive used to control microbes.

Nitrate

Nitrate in drinking water at levels above 10 ppm is a health risk for infants less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Arsenic

While your drinking water meets the EPA standard for arsenic, it does contain low levels of arsenic. the

EPA standard balances the current understanding of arsenic possible health effects against the cost of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems

Lead and Copper

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Baltimore Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in you home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

Total Trihalomethanes (TTHM'S)

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. The Village of Baltimore levels were not in excess of the MCL.

How do I participate in decisions concerning my drinking water?

Public participation and comment are encouraged at regular meetings of Village Council which meets the second and fourth Monday of each month at 7:30pm.

For more information on your drinking water contact Teri Wise at 740-862-4491 or by email at twise@baltimoreohio.org.

Definitions of some terms contained within this report

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant level (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Parts per Million (ppm) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.

Parts per Billion (ppb) or Micrograms per Liter ($\mu\text{g/L}$) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest residual disinfectant level allowed.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of residual disinfectant below which there is no known or expected risk to health.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

The A<A symbol: A symbol which means less than. A result of <5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.

Picocuries per liter (pCi/L): A common measure of radioactivity.

IDSE: Initial Distribution System Evaluation